

APA IESIRE UZINA DECEMBRIE 2007

Nr.def	Dep.A3	Nr.crt.	Indicator calitate Data	UM	Valori laborator 04.12.2007	Valori laborator 11.12.2007	Valori laborator 18.12.2007	Valori laborator	Valori medie
3	0	1	Turbiditate	°FNU	2,26	0,65	0,31		1,04
3	0	2	Conductivitate	µs/cm	361	430	420		403,6
3	0	3	pH	unit pH	7,43	7,73	7,04		7,4
3	0	4	Aluminiu	mg/l	0,018	0,003	0,028		0,016
3	0	5	Amoniu	mg/l	0,024	0,085	0,033		0,047
3	0	6	Azotiti	mg/l	0,07	0,01	0,009		0,005
3	1	7	Fier	mg/l	83	123	40		82
3	0	8	Azotati	mgO2/l	1,92	1,88	1,26		1,68
3	1	9	Oxidabilitate	mg/l	2,08	6,4	1,36		3,28
3	2	10	Clor rez.liber	mg/l	1,1	0,6	1,1		0,93
3	0	11	Clor total	mg/l	1,2	0,7	1,2		1,03
3	0	12	Cloruri	° germ.	22	27	39		29,3
3	0	13	Duritate totala	mg/l	6,78	9,87	7,68		8,11
3	0	14	Sulfati	mg/l	24,97	65,28	11,52		33,92
		15	Gust	mg/l	acceptabil	acceptabil	acceptabil	acceptabil	acceptabil
		16	Miros	mg/l	acceptabil	acceptabil	acceptabil	acceptabil	acceptabil
		17	Culoare	mg/l	acceptabil	acceptabil	acceptabil	acceptabil	acceptabil

Nr. analize fizico-chimice =

51 conf-48
neconf-3