

SISTEM APA Rastolita

Element	UM	2007	2011	2013	2015	2018	2021	2030	2037
Populatie totala	persoane	2.230	2.228	2.225	2.220	2.215	2.209	2.198	2.187
Procent operare	%	0%	74%	81%	89%	100%	100%	100%	100%
Populatie conectata	persoane	0	1.643	1.808	1.970	2.215	2.209	2.198	2.187
Debit specific	l/pers/zi	0	80	80	80	80	80	80	80
Consum total	m3/zi	0	131	145	158	177	177	176	175
Necesar apa (casnic)	m3/zi	0	131	145	158	177	177	176	175
Consum institutional	m3/zi	0	2	2	2	2	2	2	2
Consum industrial	m3/zi	0	1	1	1	2	2	3	3
Total (non casnic)	m3/zi	0	3	3	3	4	4	5	5
Cerinta apa: Casnic si non-casnic	m3/zi	0	134	148	161	181	181	181	180
Cerinta apa: Casnic si non-casnic	1000m3/an	0	49	54	59	66	66	66	66
Pierderi	%	25%	25%	25%	25%	25%	25%	25%	25%
Necesar sursa	m3/zi	0	168	185	201	226	226	226	225
Necesar total sursa	1000m3/an	0	79	87	95	107	107	107	106

Nota: Sistemul este compus din localitatile: Rastolita, Andreneasca, Borzia, Galaoaia, Iod

Source necessary

